

Ken

From: Billy Spellerberg <spellerbergenterprises@gmail.com>
Sent: Thursday, March 02, 2023 2:07 PM
To: ken@kspc.net
Subject: 3218 Enoch / PRRES20221051
Attachments: IMG-0700.jpg; IMG-0583.jpg; IMG-0702.jpg

Ken,

We installed a double sliding glass door at the rear of the great room instead of 4 fixed windows at 3218 Enoch. We have a 14" LVL above this door.

The inspector has asked to have you verify or OK of this framing is good or not.

Please advise

Thanks,

Billy

2 @ 14" LVL IS SUFFICIENT FOR THE DBL
SLIDING DOOR OPT, ~ 11' SPAN w/ 2 STUD
SUPPORT.

