CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #:PRRES20224485Address:1637 SW ARBORWAY TER, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspec	tion:	Inspector:	Outcome:	Date:
Occupa Reside	ancy Inspection - Codes Intial	Shawn Hoffman	Failed	Thursday, March 09, 2023
Correct	tive Action Required:			
1	Misc	-splash blocks and sump pump discharge to extend 36" from foundation -sod		

-will check water meter at time of sod ensure meter well to grade and meter in well 14"-18" from lid of meter to ring of well -gypsum board underneath stair area in basement

Comments: