

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20222875
Address: 365 NW PATCH CT, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Alex Fischer	Failed	Thursday, March 09, 2023

Corrective Action Required:

1	Misc	- splash blocks-Foundation drainage need to extend 36' from foundation, existing ones are too short -address grounding rod protruding from sod near electrical service entrance
---	------	--

Comments: