

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20220635
Address: 1916 NE PARK RIDGE DR, LEES SUMMIT, MO 64064
Inspected On: Thursday, March 09, 2023
Inspected By: Khanh Nguyen
Expiration Date: 4/8/2023 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
-------------	------------	----------	-------

Occupancy Inspection - Codes Residential	Khanh Nguyen	Pending	
---	--------------	---------	--

Corrective Action Required:

1	Misc	-Sod, downspout and sump pump extension -Seal exterior wall penetrations; seal above meter, AC disconnect, seal exterior lights, etc
---	------	--