

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20204934

Address: 1442 NE DOUGLAS ST, LEES SUMMIT, MO 640861444 NE DOUGLAS ST, LEES SUMMIT, MO  
640861446 NE DOUGLAS ST, LEES SUMMIT, MO 640861440 NE DOUGLAS ST, LEES  
SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>In-wall Inspection</b>	Mark Harding	Failed	Thursday, March 09, 2023

Corrective Action Required:

1	Miscellaneous Correction	EXTERIOR WALL SHEATHING OK TO COVER ROOF SHEATHING NAILING APPROVED OK TO COVER
---	-----------------------------	--

provide truss plans, nail dbl truss, provide fix on truss at the NE corner of building.

recall when plans are on site.

**Comments:**