

Temporary Certificate of Occupancy

Permit #: PRRES20214712
Address: 792 NE ALGONQUIN ST, LEES SUMMIT, MO 64064794 NE ALGONQUIN ST,
LEES SUMMIT, MO 64064790 NE ALGONQUIN ST, LEES SUMMIT, MO
64064
Inspected On: Thursday, March 09, 2023
Inspected By: Khanh Nguyen
Expiration Date: 4/8/2023 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Pending	

Corrective Action Required:

- 1 Misc Exterior:
-Final grade, sod, splash blocks
- Unit 792:
-Exterior not inspected at this time
-Water meter is buried
-Provide sewer tracer wire port at grade
-Install floodlight bulbs at rear
- Unit 794:

-Complete exterior, deck, etc

**TCO approved for unit 792 and 794 only