

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20221526
Address: 904 NW PRYOR RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection	Mark Harding	Partial	Thursday, March 09, 2023

Corrective Action Required:

1	Misc	APPROVED FOR SERVICE-
		WHEN 800AMP MAIN IS INSTALLED- LABELING NEEDS TO CHANGE.

Comments: