

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20226266  
Address: 2122 NW KILLARNEY LN, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Shawn Hoffman	Failed	Thursday, March 09, 2023

Corrective Action Required:

- |   |      |   |
|---|------|---|
| 1 | Misc | <ul style="list-style-type: none"><li>- Fire block end of soffit vertical to horizontal by DWV north wall</li><li>- Fire block around top of chase at steel columns next to stairs</li><li>- Provide combustion air intakes 12" from ceiling and 12" from floor ( check at final)</li><li>- Sheet rock under stairs ( check at final)</li></ul> |
|---|------|---|

**Comments:**