

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213812
Address: 4728 NE FREEHOLD DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Failed	Friday, March 10, 2023

Corrective Action Required:

1	Misc	-The back corner of lot not draining properly**There is still standing water; also fill in soil at eroded area at sump pump discharge pipe
		-Install splash block at rear
		-Fb floor opening under master bathroom tub **pack tight with insulation

Comments: