CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20220897

Address: 1002 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811004 NW BLACK TWIG CIR, LEES SUMMIT, MO

640811006 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811008 NW BLACK TWIG CIR,

LEES SUMMIT, MO 640811000 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Occupancy Inspection - Devon Perry Temporary C of O Friday, March 10, 2023

Engineering

Corrective Action Required:

1 Misc We are good to go on TCO.

Punch list items-

- 1. Two SW panels in front of 1000 at the bend are out of compliance
- 2. Two water meters i believe for 1002 and 1004 (currently the 2 behind the porta potties) are very shallow. 14-18" from top of meter to bottom of lid is

what they should be set at

- 3. Finish pouring SW that isn't in yet
- 4. Vegetation

Comments: