



LEE'S SUMMIT
MISSOURI



FIRE DEPARTMENT

Prevention Division
(816)969-1300

PLAN REVIEW CONDITIONS

March 10, 2023

Forge Construction LLC
1307 Union Avenue
Kansas City, MO 64101

Permit No: PRCOM20230813
Project Title: WESTLAKE ACE HARDWARE
Project Address: 3511 SW MARKET ST, LEES SUMMIT, MO 64082
Parcel Number: 267641
Location:
Type of Work: NEW COMMERCIAL
Occupancy Group: MERCANTILE
Description: NEW BUILDING FOR HARDWARE STORE

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Development Services Department (816) 969-1200

Fire Department (816) 969-1300

Fire Plan Review

Reviewed By: Jim Eden

Rejected

1. 2018 IFC 907.1.1- Construction documents. Construction documents for fire alarm systems shall be submitted for review and approval prior to system installation. Construction documents shall include, but not be limited to, all of the following: 1. A floor plan which indicates the use of all rooms. 2. Locations of alarm-initiating and notification appliances. 3. Alarm control and trouble signaling equipment. 4. Annunciation. 5. Power connection. 6. Battery calculations. 7. Conductor type and sizes. 8. Voltage drop calculations. 9. Manufacturers, model numbers and listing information for equipment, devices and materials. 10. Details of ceiling height and construction. 11. The interface of fire safety control functions.

Action required- Provide shop drawings for review and approval.

2. 2018 IFC 506.1- Where required. Where access to or within a structure or an area is restricted because of secured openings or where immediate access is necessary for life-saving or fire-fighting purposes, the fire code official is authorized to require a key box to be installed in an approved location. The key box

shall be of an approved type and shall contain keys to gain necessary access as required by the fire code official.

Action required- Provide a Knox box 6' AFF over the FDC.

3. 2018 IFC 901.2- Construction documents. The fire code official shall have the authority to require construction documents and calculations for all fire protection systems and to require permits be issued for the installation, rehabilitation or modification of any fire protection system. Construction documents for fire protection systems shall be submitted for review and approval prior to system installation.

Action required- Provide shop drawings for review and approval.

4. Complete a Hazardous Materials Permit Application for LPG exchange and bottle refilling. Provide information and drawings for the refilling area.

5. Provide an exit sign over door 107 hall. Exit signage chevrons shall point to the nearest exit.

6. 2018 IFC 906.2- General requirements. Portable fire extinguishers shall be selected, installed and maintained in accordance with this section and NFPA 10.

Action required- Provide an ABC type fire extinguisher at the 107 hallway.

Building Plan Review

Reviewed By: Joe Frogge

Rejected

1. The building permit for this project cannot be issued until the Development Services Department has received, approved, and processed the Final Development Plan.

Action required: Comment is informational.

2. 2018 IBC 1704.2 Special inspections. Where application is made for construction as described in this section, the owner or the registered design professional in responsible charge acting as the owner's agent shall employ one or more approved agencies to perform inspections during construction on the types of work listed under Section 1705. These inspections are in addition to the inspections identified in Lee's Summit Code of Ordinances Chapter 7. (see code section for exceptions)

Action required: Provide statement of special inspections / letter of responsibility from company contracted to perform special inspections.

3. 2018 IMC 306.5 Equipment and appliances on roofs or elevated structures. Where equipment requiring access or appliances are located on an elevated structure or the roof of a building such that personnel will have to climb higher than 16 feet above grade to access such equipment or appliances, an interior or exterior means of access shall be provided. Such access shall not require climbing over obstructions greater than 30 inches in height or walking on roofs having a slope greater than 4 units vertical in 12 units horizontal. Such access shall not require the use of portable ladders. Where access involves climbing over parapet walls, the height shall be measured to the top of the parapet wall. Permanent ladders installed to provide the required access shall comply with the following minimum design criteria: 1. The side railing shall extend above the parapet or roof edge not less than 30" (see code section for additional construction requirements)

Action required: Provide side rail extender at roof hatch ladder.

4. 2018 IBC Exit Signs 1013.1 Where Required. Exits and exit access doors shall be marked by an approved exit sign readily visible from any direction of egress travel. The path of egress travel to exits and within

exits shall be marked by readily visible exit signs to clearly indicate the direction of egress travel in cases where the exit of the path of egress travel is not immediately visible to the occupants. Intervening means of egress doors within exits shall be marked by exit signs. Exit sign placement shall be such that no point in an exit access corridor or exit passageway is more than 100 feet or the listed viewing distance for the sign, whichever is less, from the nearest visible exit sign. (see code section for exceptions)

Action required: Provide exit sign that leads into Hall 107.

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.