

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20216551
Address: 3225 SW MARY ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Alex Fischer	Failed	Monday, March 13, 2023

Informational:

1 Misc - portal frame passé

Corrective Action Required:

2 Misc

- provide column for porch roof
- seal penetrations electrician are making during inspection
- Complete bathroom vent near mud room
- insulating without approval

Comments: