

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20216390
Address: 1705 SW 27TH ST, LEES SUMMIT, MO 64082
Inspected On: Monday, March 13, 2023
Inspected By: Mitchell Schwarz
Expiration Date: 4/12/2023 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
-------------	------------	----------	-------

Occupancy Inspection - Codes Residential	Mitchell Schwarz	Pending	
---	------------------	---------	--

Corrective Action Required:

1	Misc	-sod -splash blocks and sump pump discharge to extend 36" from foundation -check water meter at time of sod. (Ensure meter well flush height and meter depth in well 14"-18")
---	------	---

Corrective Action Required:

2	Misc	TCO extention approved
---	------	------------------------