



September 27, 2022

Pat Cochran Concrete

Re: 2058 NW O'Brien Rd
Lot 144 Woodside
Lee's Summit, MO
PRRES20222996

Apex Engineers, Inc. observed the preparation for the garage slab at the above referenced address.

The garage slab will be suspended. The forms and reinforcing steel were found to be clean, well aligned, properly supported, and in general compliance with the approved prints.

Note:

- The inspection was performed from 11:30am.
- At the time of the inspection, the temperature was 77°.

Our firm recommends approval of the garage slab for the placement of concrete. This report does not constitute approval by the enforcing jurisdiction

LIMITATIONS

The recommendations and conclusions given in this report are based on the observed conditions at the time of this site visit. The scope of our services was only to observe the installation of the slab formwork and reinforcing steel.

Please call if Apex Engineers, Inc. can be of further assistance.

Best Regards,

Stephen Fitch
Inspections Manager

Clayton J. Hoss
Principal

