

CITY OF LEE'S SUMMIT CODES ADMINISTRATION

220 SE GREEN ST. P.O.BOX 1600 PHONE: 816-969-1200

FAX:

816-969-1201

TemporaryCertificate of Occupancy

Permit #: PRCOM20111175

Address: 699 NW BLUE PKWY, LEES SUMMIT, MO 64086

Inspected On: Friday, May 20, 2011

Inspected By: John Borns

Expiration Date: 6/2/2011 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection: Inspector: Outcome: Date:

Occupancy Inspection - John Borns Temporary C of O Friday, May 20, 2011

Codes Commercial

Corrective Action Required:

1 MISC RESOLUTION OF SHELL PERMIT ISSUES IN PROGRESS

Sprinkler - Hydrostatic Passed Friday, May 20, 2011

Test

Sprinkler - Flow Test Passed Friday, May 20, 2011

Alarm Test Passed Friday, May 20, 2011

Comments: