



AEC
**ARCHITECTURAL ENGINEERING
CONSORTIUM, INC**
ARCHITECTURE • MECHANICAL • ELECTRICAL
PLUMBING • STRUCTURAL • FIRE PROTECTION
10233 MILLSTONE DRIVE, #4112
LENEXA, KS 66220
p: 816-916-4675

March 14, 2023

Permit No: PRCOM20230845

Project Title: New Longview – Building 31 Landlord HVAC

Project Address: 420 SW Longview Blvd: Unit 100, Lee's Summit, MO 64081

Parcel Number: 272031

RE: HVAC for Future Tenants

To the City of Lee's Summit,

In response to the comments for the above permit submittal, the engineer of record has the following responses:

5. Provide Roof Curb Details.

Response: See attached revised drawing M101 for the addition of the roof mounted equipment detail.

7. Provide FCU Support Details.

Response: See attached revised drawing M101 for the addition of the suspended equipment hanging detail.

8. Condensate piping noted to be routed to floor drains that do not exist. Clarify.

Response: The floor drains in the bathrooms are existing. No changes made.

Please let me know if you have questions or need additional information.

Best Regards,

Michael Welch, PE
Principal

**ARCHITECTURAL ENGINEERING
CONSORTIUM, INC**