

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20225681
Address: 2405 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Residential	Mitchell Schwarz	Not Ready	Tuesday, March 14, 2023

Corrective Action Required:

1	Misc	Support interior drain tile at floor level to flow properly to sump pit. Reinspection required. Reinstall erosion control prior to next inspection. Drain tile not addressed -Mitchell Schwarz 3/14/23 1:25pm
---	------	---

Comments: