

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20220570

Address: 1100 NW MAIN ST, Unit:FP, LEES SUMMIT, MO 640861100 NW MAIN ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Electrical Inspection - Commercial	Khanh Nguyen	Partial	Thursday, March 16, 2023

Informational:

1	THE FOLLOWING AREAS ARE APPROVED	<ul style="list-style-type: none">-Conduit on north end, line q1 to r/t 1-2 for main power and future use-Conduit at south end line Q10 to line 9T-Conduit at line 1 at R.1 to riser room-Conduit for future use panels between line j and k from 1-10- BLDG 1 CONDUIT BETWEEN LINES B & C (2) 4" 210', BETWEEN LINES C & D (4) 4" 210' -- BLDG # 1 UNDERSLAB CONDUIT (2) 4" CROSSSLAB SOUTH TO NORTH AT LINE C (4) 4" CROSSSLAB SOUTH TO NORTH AT LINE D --Conduits at north end, line 1 from R to K/L; conduits at south end, line 10 from R to A
---	----------------------------------	---

Comments: