

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20225569
Address: 2012 NE BLUESTONE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Failed	Thursday, March 16, 2023

Corrective Action Required:

1	Misc	-Anchor sill plates within 12" of added garage door
		-Reroute refrigerator water line and protect if required **Protect water line
		-Provide security blockings at exterior door to patio
		-Protect wiring at wall across stair
		-Provide min clearance from top of fireplace **Remove wood below the triangular spacers
		-Install hangers at basement stair wall **Nail the hanger at lvl connection

Comments: