

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215859
Address: 1605 SW 27TH ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Thursday, March 16, 2023

Corrective Action Required:

1	Misc	-address pending sidewalk inspection -sod and splash blocks to extend 36" from foundation -handrail in garage required -label all non GFCI outlets in unfinished spaces -secondary locking device for rear slider -address cracked 2x10 deck joist -missing nails in hanger at deck
---	------	---

Comments: