

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20220956  
Address: 520 NE TOWN CENTRE DR, Unit:A, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Control</b>	Devon Perry	Partial	Thursday, March 16, 2023

Informational:

1	Misc	6-30-22 Gordon is installing silt fence 7-20-22 AN silt fence is still in good working order 8-4-22 AN silt fence is good but need to clean up street 9-22-22 AN no work for development 9-4-22 AN. No erosion control issues 11-30-22 AN no erosion control issues 1-5-4-23 DP no erosion control issues 1-18-23 DP no erosion control issues
---	------	---

Corrective Action Required:

2	Miscellaneous Correction	3-9-23. DP I need a contact that I can communicate with about issues with Erosion Control. There is a storm structure at the bottom of the hill by the stop sign that has a lot of sediment not allowing water to drain. I personally made it functionable last rain storm. Please send me a contact at devon.perry@cityofLS.net or 816-317-5705.  3-17-23 DP. Still have not received a contact about erosion control issues.
---	-----------------------------	--

Comments: