

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20215859  
Address: 1605 SW 27TH ST, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Mitchell Schwarz	Failed	Friday, March 17, 2023

Corrective Action Required:

1	Misc	-address pending sidewalk inspection -sod and splash blocks to extend 36" from foundation -handrail in garage required 311.7.8.5 -label all non GFCI outlets in unfinished spaces -handrail to basement missing screw
---	------	---

**Comments:**