

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20221120  
Address: 1037 SW ARMIE ST, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Control</b>	Steve Robbins	Failed	Friday, March 17, 2023

Corrective Action Required:			
1	DCM3 ESC REQUIRED 2 DAY	EROSION CONTROL REQUIRED. EROSION CONTROL SHALL BE IN COMPLIANCE WITHIN TWO BUSINESS DAYS.  -REPAIR SILT FENCE - REMOVE GRAVEL AND DEBRIS FROM STREET	
Corrective Action Required:			
2	Miscellaneous Correction	Need to make sure all silt fence is up. Gutter buddy's near house needs to be cleaned out. Keep mud and silt on site and out of the street and curb inlets.	

**Comments:**