

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20225301
Address: 400 SE BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Line - Construction Inspection	John Jackson	Passed	Friday, March 17, 2023

Informational:

1	Misc	03/17/23 Friday JMJ (She Digs It) Contractor relocated the fire hydrant that was installed by Rodriguez Construction in a recent construction phase. Contractor installed 6"X6" Tee and 6" gate valve all fitting mega lugged or anchored. Backing blocks poured behind 6"X6" Tee and anchor for hydrant.
---	------	--

Comments: