

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20222621
Address: 2071 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Kyle Beard	Failed	Monday, March 20, 2023

Corrective Action Required:
2 Misc

- missing plate covers in garage
- Garage pantry door will not self close
- Label non GFCI at pump
- Need final grade and sod
- Missing splash blocks
- Sump pump discharge missing extension
- Water meter depth needs to be 14-18 inches, currently at 20 inches

Comments: