

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20223002
Address: 2043 SW HOOK FARM DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Kyle Beard	Failed	Monday, March 20, 2023

Corrective Action Required:

1	Misc	-address deck post to beam connections (not addressed to code -missing nails in deck joist hangers - Items are not properly addressed at the time of inspection 03/20/2023. Kyle
---	------	--

Comments: