

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20213548
Address: 2100 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Miscellaneous Inspection	Robb Popp	Partial	Tuesday, March 21, 2023

Informational:
1 Misc

****Pre final for units only**
-Rooftop, common areas, corridors, stairwells, mechanical and electrical rooms not inspected

All units approved except as noted:

101,102,201,202,301,302-countertop can only overhang island receptacle max 6" and must be within 12" of top

Comments: