

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20225233
Address: 3073 NW THOREAU LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Building Inspection - Residential	Shawn Hoffman	Failed	Wednesday, March 22, 2023

Corrective Action Required:

1	Misc	- Water hammer device at washer - Provide blank at electrical panel - Label sub panel
---	------	---

Comments: