

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20226039

Address: 2117 SW OSAGE DR, LEES SUMMIT, MO 640822115 SW OSAGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Service Inspection - Residential	Mitchell Schwarz	Failed	Wednesday, March 22, 2023

Corrective Action Required:

1	Misc	2115
		-provide working pressure gauge with minimum 10 psi
		2117
		okay

Comments: