

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20226039

Address: 2117 SW OSAGE DR, LEES SUMMIT, MO 640822115 SW OSAGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Wednesday, March 22, 2023

Corrective Action Required:

1	Misc	okay to insulate
		2115
		okay
		2117
		-address over drilled floor joist above electrical panel
		-ufer ground connection to remain accessible

Comments: