

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20225022
Address: 3501 SW MARKET ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Shawn Hoffman	Failed	Thursday, March 23, 2023

Corrective Action Required:

1	Misc	- fire block penetrations in separation wall in Dr. office south west corner
		Leave ceiling open at affected area

Comments: