

SPELLERBERG

2310 SW SERENA PL.

PRRES20221048

- (2) STUD PACKS FOR 'T' BEAM SUPPORT OPT
OK AS FRAMED
- (4) HOLES ARE WITHIN 2' OF THE SUPPDT,
BENDING IS MINIMAL IN THIS REGION AND
SHEAR GOVERNS, ELECTRICAL HOLE IS $\sim 1\frac{3}{4}"$ OK
- (11) 2x4 WALL @ CLOSET, UNBRACED LENGTH
LESS THAN 10', OK AS FRAMED

