

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20216257
Address: 3226 SW PERGOLA PARK DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Alex Fischer	Failed	Friday, March 24, 2023

Partial Correction:

Corrective Action Required:

1	Misc	- sidewalk inspection pending - Final grading and sod - Splash blocks - Sump discharge minimum of 36" away from foundation - Gravel in Egress window well both sides
---	------	--

Corrective Action Required:

Comments: