

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20215280

Address: 3659 NE AKIN DR, Unit:B, LEES SUMMIT, MO 640643659 NE AKIN DR, Unit:C, LEES SUMMIT, MO  
640643659 NE AKIN DR, Unit:D, LEES SUMMIT, MO 640643659 NE AKIN DR, Unit:A, LEES  
SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	Khanh Nguyen	Failed	Monday, March 27, 2023

### Corrective Action Required:

1	Misc	EXTERIOR: -Final grade, sod, splash blocks -Seal lights and wall penetrations; flashing above service protrusion -Secure AC whips within 12" of disconnects  UNIT A: -Install shut off device at aux drain pan  UNIT B: -Install shut off device at aux drain pan  UNIT C: -Smoke/CO alarm not interconnected -Install shut off device at aux drain pan  UNIT D: -Install shut off device at aux drain pan
---	------	--

**Comments:**