

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20224156
Address: 512 NE PROMISED VIEW DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Foundation Inspection - Residential	Khanh Nguyen	Failed	Monday, March 27, 2023

Corrective Action Required:

1	Misc	Provide engineer detail for the foundation wall. The plan calls for 18"x18' wall, but 12" wall is formed. Reinforcement detail lacking on the plan
		**3/27-Footing under 18' wall must be resolved first before the foundation wall inspection

Comments: