## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

## **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #: PRCOM20223181

Address: 1401 NW RIVER RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

**Underground Electrical** Robb Popp Partial Monday, March 27,

Inspection - Commercial 2023

Informational:

1 Misc - 10/05/22 30' FOOTING 6"X6" MAT GRID FOR 8' CMU WALL SOUTH OF

BLEACHERS NEAR TRANSFORMER PAD.

UFER CLAMP IN CENTER OF FOOTING RUN TO TRANSFORMER PAD -

3/2/23

Conduit for services and lights north of fields 9 and 10 ending just west of

field 9

3/27/23

Conduit for service If3 at restroom/concession wall west of field 9

**Comments:**