

3/27/23

Joe Frogge
Codes Administration
220 SE Green Street
Lee's Summit, MO 64063

Re: Re-submittal
Summit Orchard
400 NW Chipman Road
PRCOM20230889

Dear Joe:

Attached is an electronic copy of the revised plans. My response comment numbers below correspond to your review comment numbers.

BUILDING PLAN REVIEW

1. Understood.
2. Understood
3. The parapet heights have been raised to screen the roof top units.
4. The cleanout has been shown
5. The MEP plans have been revised to match site Utility Plan #10


LICENSED CONTRACTORS

1. Understood
2. Understood

FIRE PLAN REVIEW

1. Understood
2. Understood

Sincerely,



Jeff Schroeder, RA, President
Herman A. Scharhag Co., Architects