

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20226039

Address: 2117 SW OSAGE DR, LEES SUMMIT, MO 640822115 SW OSAGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Ryan Heckman	Partial	Tuesday, March 28, 2023

Informational:

1	Misc	3-28-23 RH. Driveway is formed up and aggregate is placed and compacted. Approved to pour.
---	------	--

Comments: