

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20225389
Address: 2909 NW AUDUBON LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Wednesday, March 29, 2023

Corrective Action Required:

1	Miscellaneous Correction	- provide sill plate anchor at plate break no more than 12" from end and at least 5x the diameter of bolt from the end.
---	--------------------------	---

not donr Shawn Hoffman 03/29/2023 11:53 AM

Comments: