

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRSUBD20221459  
Address: 3221 SW PERGOLA PARK DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Water - Material Verification</b>	Eric Sharp	Passed	Wednesday, March 29, 2023

Informational:

1 Misc

Materials delivered from Win-Water:

69 sticks of 8" C900

3 sticks of 6" C900

5 Kennedy K81D hydrants with black epoxy coated shoes

6" and 8" Mega lugs, gaskets

8" fusion bonded epoxy tees

Fusion bonded epoxy bends and sleeves

coated blue tee bolts/nuts

polywrap/tape

Also had SDR35 pipe delivered (presumably to use as valve box/riser)

informed Adam and Laif this was not an approved material for valve boxes

and they would need to replace this with C900 pipe and probably correct

their lids with their supplier to get lids that will fit C900 pipes wider OD.

10/7/22 ES

**Comments:**