

**DEVELOPMENT SERVICES**

**PLAN REVIEW CONDITIONS**

March 30, 2023

COLLINS WEBB ARCHITECTURE LLC  
307 SW MARKET ST, Unit B  
LEES SUMMIT, MO 64063

Permit No: PRCOM20231099  
Project Title: JOHN KNOX VILLAGE - RESTAURANT  
Project Address: 1001 NW CHIPMAN RD, LEES SUMMIT, MO 64081  
Parcel Number: 62120014200000000  
Location / Legal: JOHN KNOX RETIREMENT VILLAGE 4TH PLAT TRACT-1 & E 1/2 VAC ST LY W OF & ADJ  
Description:  
Type of Work: ALTERATION COMMERCIAL  
Occupancy Group:  
Description: TENANT IMPROVEMENT RENOVATION TO EXISTING RESTAURANT SPACE TO UPGRADE  
FIXTURES, FINISHES, AND FURNISHINGS THROUGH DINING AREA, LOBBIES, BANQUET ROOMS  
AND RESTROOMS.

***Revisions Required***

***One or more departments have not approved the permit and the following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please address the comments as requested and upload the revised documents and /or additional information to the application through the online portal. Please contact the appropriate department regarding clarification of comments.***

Development Services Department (816) 969-1200

Fire Department (816) 969-1300

**Licensed Contractors**

**Reviewed By: Joe Frogge**

**Rejected**

1. Lee's Summit Code of Ordinance, Section7-130.10 - Business License. It shall be unlawful for any person to engage in the construction contracting business without first obtaining a business license as required under the applicable provisions of Chapter 28 of the Lee's Summit Code of Ordinances.

Action required: Either a Class A or Class B license is required. Provide the company name of the licensed general contractor and an email address & phone number for the on-site contact which is where inspection reports will be sent.

2. Lee's Summit Code of Ordinance, Section7-130.4 - Business License. (excerpt)

No person, other than a licensed contractor or employees of a licensed contractor, shall engage in electrical, plumbing or mechanical business, construction, installation or maintenance unless duly licensed in accordance with this section.

Action required: MEP subcontractors are required to be listed on permit. Provide company names of licensed MEP contractors.

**Building Plan Review**

**Reviewed By: Joe Frogge**

**Rejected**

---

**DEVELOPMENT SERVICES**

1. For the Health Department review contact Deb Sees with the Jackson County Public Works Department, Environmental Services Division, at (816) 847-7070. Health Department approval is required prior to receiving any type of building permit from the City of Lee's Summit.

Action required: Comment is informational.

2. For the Health Department inspection contact Deb Sees with the Jackson County Public Works Department, Environmental Health Division at (816) 847-7070. Health Department approval is required prior to receiving any type of Occupancy from the City of Lee's Summit.

Action required: Comment is informational.

**Fire Plan Review**

**Reviewed By: Jim Eden**

**Rejected**

1. 2018 IFC 907.1.1- Construction documents. Construction documents for fire alarm systems shall be submitted for review and approval prior to system installation. Construction documents shall include, but not be limited to, all of the following: 1. .A floor plan which indicates the use of all rooms. 2. Locations of alarm-initiating and notification appliances. 3. Alarm control and trouble signaling equipment. 4. Annunciation. 5. Power connection. 6. Battery calculations. 7. Conductor type and sizes. 8. Voltage drop calculations. 9. Manufacturers, model numbers and listing information for equipment, devices and materials. 10. Details of ceiling height and construction. 11. The interface of fire safety control functions.

Action required- Provide alarm shop drawings for review and approval to devservices.cityofls.net.

2. 2018 IFC 901.2- Construction documents. The fire code official shall have the authority to require construction documents and calculations for all fire protection systems and to require permits be issued for the installation, rehabilitation or modification of any fire protection system. Construction documents for fire protection systems shall be submitted for review and approval prior to system installation.

Action required- Provide sprinkler shop drawings for review and approval to devservices.cityofls.net.

3. 2018 IFC 901.6- Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be maintained in an operative condition at all times, and shall be replaced or repaired where defective. Not required fire protection systems and equipment shall be inspected, tested and maintained or removed.

Information only- The existing sprinkler system shall have documentation of a current annual inspection.

4. Provide panic hardware on door 110C.

***The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.***