

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20221459
Address: 3221 SW PERGOLA PARK DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sanitary Sewer - Mandrel	Ryan Heckman	Partial	Thursday, March 30, 2023

Informational:

1 Misc

Mandrel passed between sections:

B5-B4
B4-B3
B3-B2
B2-B1
B1-A4
A7-A8
A5-A6

Mandrel failed section A6-A7. Dug up line and found pipe had smashed/collapsed. Replaced 2 sections of pipe using solid SDR26 fittings and performed a preliminary test and had success. 11/11/22 ES

Pulled Mandrel through section A4-A5 and A3-A4. passed. 11/21/22 ES

3-30-23 RH. Sanitary Line A3-A2 will be cleaned out and then mandral will be pulled through.

Comments:

