

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215799
Address: 1509 SW 27TH ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	Ryan Heckman	Failed	Thursday, March 30, 2023

Informational:
1 Misc 3-30-23 RH. Sidewalk was inspected pre pour and found to have not enough rock in some areas closer to the ADA ramp. There was visible dirt where there should be 4" of aggregate. Not approved to pour.

Comments: