



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20110307, Building Permit - Commercial
Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	John Borns	Partial	Wednesday, May 25, 2011

Partial Correction
1 MISC

OK TO COVER WHEN READY CEILING FRAMING AND ABOVE-CEILING SYSTEMS AT FOLLOWING SPACES: PHASE I (ENSURE ONE ELECT J.B. IS CLOSED WHEN TEMPORARY POWER FEED IS REMOVED);

Comments: