

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20220956
Address: 520 NE TOWN CENTRE DR, Unit:A, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Khanh Nguyen	Partial	Monday, April 03, 2023

Informational:

1 Misc

6-30-22 Gordon is installing silt fence
7-20-22 AN silt fence is still in good working order
8-4-22 AN silt fence is good but need to clean up street
9-22-22 AN no work for development
9-4-22 AN. No erosion control issues
11-30-22 AN no erosion control issues
1-5-4-23 DP no erosion control issues
1-18-23 DP no erosion control issues
3-31-23 DP. Erosion control issues have been handled and is currently in good working order.
4-3-23 NS. No Erosion control issues.

Corrective Action Required:

2 Miscellaneous
Correction

3-9-23. DP I need a contact that I can communicate with about issues with Erosion Control. There is a storm structure at the bottom of the hill by the stop sign that has a lot of sediment not allowing water to drain. I personally made it functional last rain storm. Please send me a contact at devon.perry@cityofLS.net or 816-317-5705.

3-17-23 DP. Still have not received a contact about erosion control issues.

Comments:

