

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20226055
Address: 1421 SW GEORGETOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Kyle Beard	Failed	Monday, April 03, 2023

Corrective Action Required:

1	Miscellaneous Correction	-fire block fir down by stairs -fire block(2) living room walls every 10 feet -fire block all ceiling penetrations -framing not completed at bathroom vanity and shower areas -water lines in bathroom need nail plates -AFCI will need to be installed in living areas and GFCI installed in bathroom area. Wiring not attached to panel at the time of inspection
---	--------------------------	--

Comments: