

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20220453
Address: 2018 SW FARM FIELD LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Tuesday, April 04, 2023

Corrective Action Required:

2 Misc

- fire block north garage wall to ceiling space
- seal all penetrations in joist space used for return air above mud room
- block under cantilever at slider
- complete bath fan install bed 3
- seal penetrations in bed5 joist space used for RA

Comments: