

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20220128  
Address: 102 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sidewalk Inspection</b>	Devon Perry	Passed	Tuesday, April 04, 2023

Informational:

1 Misc

Deven Perry and I did the sidewalk inspection and it appears that the pre-pour inspection meets city standards and ADA standards. Will come back in a week to do a post-pour inspection.

4-4-23 DP. Sidewalk has been poured, cross slope is in compliance, forms removed. passed.

**Comments:**