

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20220898

Address: 1013 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811015 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811017 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811019 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811011 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	Robb Popp	Failed	Tuesday, April 04, 2023

Corrective Action Required:

1	Misc	-Complete final grade, sod, downspout extensions, etc. -Seal exterior penetrations -All water meters to be 14"-18" to top of meter pit  1015-Garage entry door to self close and latch 1017-Stair risers to vary no more than 3/8" 1019-Stair risers to vary no more than 3/8" *Roof not inspected
---	------	---

**Comments:**