

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20192646  
Address: 3201 NW PARAGON PKWY, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Foundation Inspection - Commercial</b>	Robb Popp	Partial	Tuesday, April 04, 2023

Corrective Action Required:

1 Misc

The following areas approved-

WEST BUILDING:

- Perimeter footing and pads completed
- Interior column pads complete
- Exterior column pads at line 1/m and 1/R
- Footing and walls for elevator pit

**\*\*UFER LOCATED AT 2/Q**

- Stem wall on West side only , N to T, framed and rebar complete. OK to pour.

EAST BUILDING 2:

- Perimeter footing and pads:  
Line 1 and 2 from A to H,  
Line A from 1 to 3.5,  
Line 4 and 5 from A to D,  
Line H from 1 to 3.5

**Comments:**